

Scott Point Waterworks District

Water Quality Summary		2021																																										
Monthly Bacteria Testing		JAN		Q 1 Wells				FEB	MAR	APR	Q 2 Wells				MAY	JUN	JUL	Q 3 Wells				AUG	SEP	Fall Big Rainfall Sep 20			OCT	Q 4 Wells				NOV	DEC											
Location	Element	Units	Limit	466	1raw	1prod	3raw	3prod	4raw	4prod	Marina	466	Marina	1raw	1prod	3raw	3prod	4raw	4prod	466	Marina	466	1raw	1prod	3raw	3prod	4raw	4prod	Marina	466	Well 1	Well 3	Well 4	Marina	1raw	1prod *	3raw	3prod	4raw	4prod *	466	Marina		
	Total Coliform	CFU/100ml	0	0	4	0	0	0	26	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Total Non-Coliform	CFU/100ml	0	0	6	0*	0	0	400	0*	0	0	0	0	0	0	0	0	6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Fecal Coliform	CFU/100ml	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Fecal Non-Coliform	CFU/100ml	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	E-coli	CFU/100ml	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Note: Well 1 & 4 product combined
* retest