

Scott Point Waterworks District

Water Quality Summary
Monthly Bacteria Testing

		2021		Q 1 Wells					FEB	MAR	APR	Q 2 Wells					MAY	JUN	JUL	Q 3 Wells					AUG	SEP	Fall Big Rainfall			OCT	Q 4 Wells					NOV	DEC	DEC						
Location		466	1raw	1prod	3raw	3prod	4raw	4prod	Marina	466	Marina	1raw	1prod	3raw	3prod	4raw	4prod	466	Marina	466	1raw	1prod	3raw	3prod	4raw	4prod	Marina	466	Well 1	Well 3	Well 4	Marina	1raw	1prod *	3raw	3prod	4raw	4prod *	466	Marina	Well 4 Raw			
Total Coliform	CFU/100ml	0	4	0	0	0	26	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2
Total Non-Coliform	CFU/100ml	0	6	0*	0	0	400	0*	0	0	0	0	0	0	0	6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	200	
Fecal Coliform	CFU/100ml	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Fecal Non-Coliform	CFU/100ml	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	54		
E-coli	CFU/100ml	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		

Note: Well 1 & 4 product combined
* retest

after pump
replacement.
All water
reprocessed
in RO