

- 3. OWNER IS RESPONSIBLE FOR CONNECTIONS TO THE SPWD FACILITIES AT DOUBLE CHECK VALVE AND HAS CHOICE OF LENGTH OF NIPPLE TO OWNER'S SHUT-OFF VALVE
- 4. OWNER'S SHUT-OFF VALVE IS RECOMMENDED TO BE 316SS. THE HANDLES ON STANDARD BRASS VALVES CORRODE QUICKLY
- 5. OWNERS SHOULD BE WARY OF OLDER "POLY" PIPE SERVICE LINES THAT MAY BE POLYBUTYL OR WEAKER IRRIGATION PIPE. THESE WILL NOT BE MARKED "POTABLE" AND SHOULD BE REPLACED





Scott Point Waterworks District

SPWD 4" DIA AC TRANSITE WATER MAIN

STANDARD WATER SERVICE CONNECTION MAIN TO PREMISES - ¾" OR 19mm

SPWD DRAWING NO.

BY/CHK
RTB

M 1.0