

Scott Point Waterworks District



Policy Number: 014

Revision: 3

Date: June, 2024

Watering Restrictions Policy

Applicable to: All residents of Scott Point Waterworks District

1. Section 31 of Bylaw 117 provides the trustees with the authority to: *introduce regulations restricting the use of Water for sprinkling or any other purpose. Due notice of restrictions shall be given either by publication in a newspaper circulating within the District or by mail or by electronic mail.*
2. Conditions which may require water restrictions to be issued:
 - Weekly static well height readings moving 10% below 5 year averages
 - Water consumption consistently exceeding normal levels for the period,
 - NSSWD and Provincial water restriction/drought levels
3. Permitted Dates are:
 - a. Even Dates for even-numbered residences,
 - b. Odd Dates for odd-numbered residences.

	No Restrictions	Stage 1 No Sprinkling	Stage 2 No pressure washing	Stage 3 Only hand watering	Stage 4 No watering
Sprinklers	4 hr on permitted dates	Not permitted	Not permitted	Not permitted	Not Permitted
Drip irrigation and Hand watering	Anytime	7pm to 8am permitted dates for 4 hr	7pm to 8am permitted dates for 2 hr	Hand watering for 1 hr	Not Permitted
Washing of vehicles, boats	Anytime	Anytime	Discouraged. permitted dates only	Not permitted	Not Permitted
Washing of decks, buildings, driveways	Anytime	Permitted dates only	Not permitted	Not permitted	Not Permitted
Filling of hot tubs & features	Anytime	Anytime	Not permitted	Not permitted	Not Permitted
Recommended Use / Premises	2500 lGal per mo.	1750 lGal per mo.	1500 lGal per mo.	1250 lGal per mo.	1000 lGal per mo.

Scott Point Waterworks District



4. Upon enactment of the Drought Plan, further Emergency Restrictions may be introduced by the trustees, including limiting consumption to 20 gallons per household per day.
5. These restrictions do not apply to the use of captured rainwater, or supply from personal wells. These supplies shall NOT be cross connected with the District system.
6. There shall be no filling of storage tanks from the District supply at any time.